



Safety & Buildings Division
201 West Washington Avenue
P.O. Box 2658
Madison, WI 53701-2658

Evaluation #

200505-H
(Replaces 980100-H)

Wisconsin Building Product Evaluation

Boilers & Water Heaters:

Manufacturer: Lochinvar Corporation
300 Maddox Simpson Pkwy.
Lebanon, Tennessee 37090

Approved Product(s): Trade Name: Power-Fin

P(B,F)N 250B, 500B, 750B and 1,000B

P(B,F)(N,L) 0501
P(B,F)(N,L) 0701
P(B,F)(N,L) 1001
P(B,F)(N,L) 1300

SCOPE OF EVALUATION: This review includes the cited: Comm code requirements in accordance with the current **Wisconsin Comm 40 (Boiler Code); Dwelling Code (UDC); International Building Code (IBC); International Mechanical Code (IMC); and International Fuel Gas Code (IFGC).**

TESTS: The water heaters and boilers bear the ASME “H” or “HLW” stamp. All units were tested and evaluated in accordance with ANSI Z21.10.3, ANSI Z21.13 or ANSI Z21.56 Standard. They were found to be acceptable to be covered under the AGA Certification Service.

LIMITATIONS OF APPROVAL: The boilers or water heaters shall be installed as allowed in **Comm 40 (Boiler Code); s. Comm 23.04** of the UDC; **s. IBC 302.1; ss. IMC 301, 303 and Chapter 10; s. IFGC 630.1 [Comm 65.0630]**, their listing and the manufacturer's recommendations.

This approval will be valid through December 31, 2010, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department. The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

DISCLAIMER: The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date:

Approval Date: April 20, 2005 By: _____

Lee E. Finley, Jr.
Product/Material &
Building Plan Review
Integrated Services Bureau

200505-H.doc